

(1) EC-TYPE EXAMINATION CERTIFICATE

(2) Equipment or protective system intended for use in potentially explosive atmospheres – Directive 94/9/EC

(3) EC-Type Examination Certificate Number: **KEMA 02ATEX2024 X**

(4) Equipment or protective system: **Electromagnetic flowmeter primary head, types IFS 5000 F/...-EEx and MGS 5000 F/...-EEx**

(5) Manufacturer: **Krohne Altometer**

(6) Address: **Kerkeplaat 12, 3313 LC Dordrecht, The Netherlands**

(7) This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

(8) KEMA Quality B.V., notified body number 0344 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report no. 2017378.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 50014 : 1997
EN 50028 : 1987

EN 50019 : 2000
EN 50281-1-1 : 1998

EN 50020 : 1994

(10) If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.


(11) This EC-Type Examination Certificate relates only to the design, examination and tests of the specified equipment or protective system in accordance with the Directive 94/9/EC. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.

(12) The marking of the equipment or protective system shall include the following:

 **II 2 GD EEx me ib IIC T6...T3**
T80...180 °C

Arnhem, 25 February 2002,

KEMA Quality B.V.



T. Pijpker
Certification Manager

* This Certificate may only be reproduced in its entirety and without any change

(13)

SCHEDULE

(14)

to EC-Type Examination Certificate KEMA 02ATEX2024 X

(15)

Description

The Electromagnetic flowmeter primary head, types IFS 5000 F/...-EEx and MGS 5000 F/...-EEx, is used to convert the flow of a conducting fluid into an electrical signal. An associated flowmeter transmitter is used to supply the field coils of the primary head and to convert the measured electrode signal into an output signal.

The field coils of the primary heads are in type of explosion protection encapsulation "m", the electrodes circuit is in type of explosion protection intrinsic safety "i" and the terminal compartment is in type of explosion protection increased safety "e".

The maximum surface temperature T80...180 °C is based on an ambient temperature of 60 °C.

Electrical data

Field coil circuit $U \leq 40 \text{ V}$ (pulsed)
 $I \leq 125 \text{ mA}$ (fuse protected)

The field coils circuit is protected by two 160 mA fuses in the coil excitation circuit of the associated transmitter.

Electrodes circuit in type of explosion protection intrinsic safety EEx ib IIC, only for connection to a certified intrinsically safe circuit, with the following maximum values:

$$\begin{array}{rcl} U_i & = & 20 \quad \text{V} \\ I_i & = & 170 \quad \text{mA} \end{array}$$

The effective internal capacitance and inductance are negligibly small.

The signal circuit is operationally grounded.

Installation instructions

For use in potentially explosive atmospheres of flammable gases, fluids or vapours:
 The cable entry device shall be in type of explosion protection increased safety "e", suitable for the conditions of use and correctly installed.

For use in the presence of combustible dust:

The cable entry device shall be in type of equipment Category II 2 D, suitable for the conditions of use and correctly installed.

Unused openings shall be closed with suitable certified closing elements.

Routine tests

Each primary head shall withstand a test voltage according to EN 50019 Clause 6.1, of 1500 V during one minute without breakdown between the field coils circuit and the enclosure and between the field coils circuit and the intrinsically safe sensor circuit.

(13)

SCHEDULE

(14)

to EC-Type Examination Certificate KEMA 02ATEX2024 X

(16)

Report

KEMA No. 2017378.

(17)

Special conditions for safe use

The relation between temperature class, maximum surface temperature, maximum process temperature and ambient temperature is shown in the following table:

Temperature class	Max. surface temperature	Max. process temperature		
		Ta ≤ 40 °C	Ta ≤ 50 °C	Ta ≤ 60 °C
T6	T 80 °C	65 °C	65 °C	65 °C
T5	T 95 °C	85 °C	85 °C	80 °C
T4	T 130 °C	125 °C	125 °C	120 °C
T3	T 180 °C	180 °C	165 °C	145 °C

Ambient temperature range -40 °C ... +60 °C (meter size DN2.5 - DN15).

Ambient temperature range -20 °C ... +60 °C (meter size DN25 - DN80).

A heat resistant cable with a continuous operating temperature of at least 120 °C must be used at the conditions as specified below:

- with Ta ≤ 40 °C and the process temperature ≥ 165 °C, or
- with Ta ≤ 50 °C and the process temperature ≥ 130 °C, or
- with Ta ≤ 60 °C and the process temperature ≥ 100 °C.

The breaking capacity of the primary fuse of the signal converter is 300 A (IFC 090, 24 V versions) resp. 1500 A (IFC090, 100-230 V and all IFC090i versions). Therefore, the signal converter may only be connected to a mains supply with a maximum prospective short circuit current of 300 A resp. 1500 A.

(18)

Essential Health and Safety Requirements

Covered by the standards listed at (9).

(19)

Test documentation

1. Certificate of Conformity KEMA No. Ex-91.C.9694 X
Component Certificate KEMA No. Ex-01.E.2036 U

dated

2. Description (14 pages)

16.05.2001, 04.02.2002
and 13.02.2002

3. Drawings index sheet

13.02.2002