

Programming Display

Quick Start

STEPS	DISPLAY	ACTION	
Main Display Press HOLD 1.		1st. Step Press and Hold Both	SE-1 Default Set to 4mA Empty
Low Level Value Press 1x	 Low Value - 4mA = 0	2nd. Step Default Preset = 000.0 No need to change Press.	
Press 2 sec		4th Step In this screen press and hold for 2 sec	
High Level Value Enter High Level Value 5.	 Enter Max Tank Value	5th Step Move cursor Change number to desired value (Note: This value is your max tank level) Inches Gallons Liters	SE-2 Set High Liquid Level Value Value = Max Fill Height Inches Gal
Press 2 sec to SAVE		6th Step Press 2 sec to SAVE	
Return to Main Display Press HOLD 6.		7th Step Press & Hold Return to Main Display	
	 Current Level Value	Finished Current Tank Level	